


## **Appendix C**

### **Utilities Analysis Background Information**



# MUNDALL ENGINEERING & CONSULTING

P.O. Box 56  
Lytton, B.C. V0K 1Z0  
Bus. (800) - 313 - 9705  
FAX (250) - 455 - 2276

P.O. Box 799  
Sumas, WA 98295  
Cellular (360)-319-1285  
FAX (360)-599-3394  
E-Mail dan@mundall.com

WATER RESOURCES    WASTEWATER    CIVIL    AGRICULTURAL

December 6, 2018

Attn: Alan Kerley, General Manager  
Lake Forest Park Water District  
4029 NE 178<sup>th</sup> Street  
Lake Forest Park, WA 98155

RE: **Impacts Resulting from Land Use Changes – LFP Town Center Site**

Dear Alan,

Further to email communication and telephone discussions with Lori McFarland and Adam Isaacson of Otak, we conducted a brief review of probable impacts resulting from several growth scenarios that are being considered for the Town Center site.

It is understood that Otak wishes to gain an idea of what type of infrastructure improvements the District might be required to make to accommodate the contemplated changes in land use. After considering their request, and the timeframe for the current study, it is agreed that a detailed examination of these impacts is not attainable presently, so a decision was made to prepare a qualitative assessment of the types of impacts that are expected and defer detailed hydraulic modeling to a later stage. In particular, analysis focused on the largest development “Alt. 3” which includes 1,500 multi-family residential units and some commercial upsizing.

Our review shows that while the contemplated land use scenarios might greatly increase customer count the District infrastructure and water rights are largely capable of supporting the demands. Additional extended period simulation hydraulic modeling is recommended to confirm these assumptions. Serious consideration should be given to water quality impacts and the possible need for another well to offset reliance on McKinnon DW#3 which has nuisance iron levels.

I hope you find this helpful and that Otak can proceed with a better understanding of possible impacts to LFPWD.

Best Regards,

Dan Mundall, MSCE, PE



DATE: / /

01/25/2020

# Evaluation of Land Use Possibilities - Town Center Subarea Plan

## Impacts to Water Supply

### Lake Forest Park Water District

#### I. Introduction

Otak Consultants are assisting the City of Lake Forest Park in evaluating environmental impacts of various land use alternatives being considered for the Lake Forest Park Town Center. These alternatives may place increased demands on the provisioning of water for domestic and commercial use and also fire suppression needs. Therefore Otak have approached the municipal water provider - Lake Forest Park Water District (LFPWD) and asked for help in identifying the nature of impacts that might be expected with various land use scenarios being contemplated in their study.

In particular, the kinds of questions asked are:

- **Adequacy of Water Source & Supply** - Does the District have adequate source & supply water to provide for the land use scenarios?
- **Adequacy of Storage** - Will more water storage be required for peak usage and fire suppression needs?
- **Adequacy of Distribution System** - are new, bigger mains required?
- **Water Quality Impacts** – What impacts might be considered?
- **Other Considerations**

The design and operation of water systems such as LFPWD is primarily regulated by State law through the Washington State Department of Health – Drinking Water (WSDOH). These design standards are delineated in their Water System Design Manual and other publications. Additionally, LFPWD has adopted design and construction standards in its Comprehensive Water System Plan 2015 that establish more specific requirements unique to the District. Fire requirements for large buildings is estimated by Insurers Services Office (ISO) based on size and construction type and these are usually developed in cooperation with the building architect at a more advanced stage of the project.

---

*"Lake Forest Park Water District strives to provide high quality water, sourced from our local aquifer, at the lowest reasonable cost, while investing in our infrastructure and maintaining the highest level of customer service."*

---



## ***II. Adequacy of Water Source and Supply System***

LFPWD is unusual among Class A municipal water providers in King County because it supplies nearly all water from its own groundwater sources and it does not normally treat its water. The District has two well fields, McKinnon Creek and Horizon View with a total of 6 deep wells and 8 shallow artesian wells. District water rights were recently pooled with Washington Department of Ecology to allow withdrawal from any of the wells, subject to operational capacity.



There are some variations in water quality between wells. McKinnon Well #3 (and Well #4 which is not connected presently) has high iron content, so water from this source is blended in controlled amounts during periods of peak demand to avoid nuisance water complaints.

The District presently has total groundwater right allocation of 973GPM. Additionally the District recently signed a 50 year agreement with Seattle Public Utilities which provides up to 3,500GPM (duration up to one week) for emergency use from the Tolt pipeline. The current physical capacity of the SPU-Tolt intertie is limited to 2,100GPM but the District is able to construct another intertie under the same agreement if needed. There are special concerns with blending and this water is only available for emergency and fire suppression needs and not for routine domestic demand.

A cursory calculation of source water required for consumptive needs follows, considering the largest development scenario **“Alt 3 – Uniform Form and Height”**:


### **Average Day Demand:**

- Assume expected additional 1,500 Multi-Family Dwellings (MFD), ignore non-residential developments as the demands are small compared with residential
- Recorded SFD Average demand is about 200GPD in LFPWD.
- Assume 1MFD = 0.75(ERU) Single Family Dwelling (SFD) based on various sources
- ERU Avg. Day due to Alt 3 =  $1500 \times 0.75 = 1,125$  count
- Average demand per MFD unit =  $200\text{GPD} \times 0.75 = 150\text{GPD}$  per unit
- Average demand proposed Alt 3 =  $150 \times 1500 = 225,000\text{GPD}$
- **Average system demand =  $225,000 + 254,000\text{GPD} = 479,000\text{GPD}$  – no issue with source capacity to supply average day for Scenario 3.**
- ERU system count =  $1279 + 1,125 = 2,404$

## Maximum Day Demand:


- Assume peaking factor 1.25 for Max Day for MFD (based on Water Research Fdn. 2018)
- Est. Max. Day Demand Alt 3 =  $1.25 \times 150 \times 1500 = 281,250\text{GPD}$  (195GPM)
- Current (2020) Max. Day System = 550GPM
- **Scenario Alt 3 Max. Day System = 550+195GPM = 745GPM < 973GPM water right.**

**Therefore water rights appear adequate to supply Max. Day Demand with the proposed alternative.**



## Peak Hour Demand:

Peak Hour periods are usually morning and evening. Various ways of estimating Peak Hour for a given system. Generally as the size of the system increases the peaking factor diminishes. In this instance we make a conservative calculation by adding the peak hour demand of Alt. 3 to the existing Peak Hour established in the District's Comprehensive Plan. For a simplified approach we will use a WSDOH formula for peak hour flow. (ref. Eq. 5-3, Table 5-1 of Water System Design Manual 2009)



$$\text{PHD} = (\text{MDD}/1440)[\text{CN} + \text{F}] + 18, \text{ assume C=1.6, F=225, MDD=150GPD/MFD, N=1500}$$

$$\text{PHD} = 360\text{GPM} + 784\text{GPM} (\text{current system 2020}) = 1,144\text{GPM}$$

**Test for source water rights 1,144GPM > 973GPM so additional equalizing storage may be necessary to meet peak hour demands of Alt 3 based on water rights. This should be further evaluated by hydraulic modeling.**

## Fire Demand:

Capacity for fire suppression in commercial structures is the dominant demand in the LFPWD network. Fortunately the District has an emergency intertie agreement with Seattle Public Utilities (SPU) which offers ample capacity to support the District's existing fire suppression need of 3,500GPM for 3 hours. However there are limitations to this capacity:

1. Presently the District is completing design and permitting for a zone pressure reducing valve that will admit this water from the "Horizon View" 550HGL zone to the "Low Zone 292HGL. Without this zone intertie water is restricted from reaching the Low Zone in adequate quantity for commercial fire suppression needs.
2. There are sections of the transmission main which limit the capacity of the intertie to a maximum of 2,100GPM. In consideration of possible future increases in fire capacity the District has identified a location where an additional intertie with the SPU-Tolt system could be constructed to provide greater capacity and reliability. This intertie would be covered as an additional withdrawal point under the existing emergency intertie agreement with Seattle and would require about 1,600 feet of transmission main to the McKinnon Creek wellfield.

### ***III. Adequacy of Storage***

The District has a total of 4 reservoirs serving three pressure zones. Most of the distribution storage in the system was constructed in the 1960's. The addition of additional demand will place increased burden on the reservoirs and this should be examined for adequacy to meet various demand scenarios. LFPWD has additional source/supply capacity through an intertie with SPU-Tolt but this is only valid for emergency scenarios such as fire.

1. **Equalizing Storage** is required to accommodate times when peak capacity exceeds source capacity.

#### Adequacy due to Water Rights limitations:

Without hydraulic modeling we can conservatively estimate equalizing storage required due to water rights using Equation 9-1 in the WSDOH System Design Manual

$$ES = (PHD - Q_s)(150\text{min})$$

Given PHD = 1,144 and water rights capacity = 973GPM

$$ES = (1,144 - 973\text{Gal/min})(150\text{min}) = 25,650\text{Gal}$$

It is likely that the existing "Low Zone" 292 Reservoir may accommodate this need. However this should be subjected to hydraulic modeling with the actual diurnal curve expected in the LFPWD network (see Diurnal curve graph on previous page).

#### Adequacy due to water quality considerations:

Water from McKinnon Deep well #3 contains high iron. If this well is blended at more than 25% there will be complaints from customers. Assuming this well is off and the District relied on other wells we have roughly 625GPM available for consumptive use:

$$ES = (1,144 - 625\text{Gal/min})(150\text{min}) = 77,850\text{Gal}$$

Storage may still be adequate in the "Low Zone" 292 reservoir to cover this need although this should be hydraulically modeled to confirm adequacy.

2. **Standby Storage** is required in WSDOH design standards to allow for unexpected limitations in the source & supply system such as power outage or pump failure.

- WSDOH standby storage Eq. 9-3 in the Design Manual assumes the largest source is out of service and does not include emergency sources:  
Standby Storage SB(system with Alt 3) =  $2 \times 200 \times 2404 - 1440(600) = 97,600\text{Gal}$  may be adequate with existing system storage although water quality issues must also be considered for this scenario. Note that this would require heavy dependence on McKinnon Well#3 which would be contributing about 1/3 of total supply. The increased iron level would certainly produce customer complaints.



## **IV. Adequacy of Distribution System**

Water distribution networks in the size range of LFPWD are dominated in design by fire protection vs. peak consumptive use. Most of the transmission and distribution network between the Low Zone reservoir and the LFP Towne Center has already been upgraded to 12" main which is adequate for the anticipated future. However there are a few sections which have been identified in the District's Comprehensive Plan as needing upgrade:



1. Project #SS1 - Low Reservoir to McKinnon Creek transmission main 90 feet will be upgraded in 2019 as part of the District's ongoing McKinnon Creek Pumphouse project.
2. Project #D10 - Ballinger Way near north entrance to LFP Town Center to 175<sup>th</sup> Street – 520ft 12" ductile iron is identified in the Comprehensive plan but not funded yet.
3. Project #D5 – 175<sup>th</sup> Street between Ballinger and 47<sup>th</sup> Ave. NE 469ft 8" ductile iron. The District is seeking funding for this project at present.

If the proposed project will result in larger demand than 3,500GPM for 3 hours then additional hydraulic modeling should be carried out to assure adequate fire suppression capacity. Obviously this is something that will be dependent on proposed building design.

## **V. Water Quality Impacts**

As identified in other sections of this memo, water quality needs to be considered in placing increased peak demands on the system. Depending on the size of development the District should consider developing a new well under existing water rights to replace the capacity offered by McKinnon DW#3 and DW#4 which does not have the nuisance iron problem otherwise there will likely be increased complaints during peak months of the year with increased reliance on McKinnon DW#3 as a result of the contemplated development.

## **VI. Other Considerations**

1. Presently water is supplied to the LFP Towne Center at the Hydraulic Grade Line (HGL) of the "Low Zone" which is 292feet. This is reduced in pressure by two pressure reducing valve stations owned and operated by the Town Center. Consideration should be given to bypassing these PRV vaults for the proposed development.
2. With increased demands on the District's Low Zone 292HGL consideration should be made as to the adequacy of the District's current infrastructure for seismic requirements and standby storage in the event of failure or servicing needs in the Low Zone reservoir.
3. Any of the proposed development scenarios will push the District's customer count past a threshold customer count for mandated security standards imposed by the Department of Homeland Security.

## ***VII. Summary Conclusions and Recommendations***

Impact to the LFPWD water system from the proposed land use scenarios was examined for the maximum impact scenario of 1,500 multi-family units presented in “Alt. 3”. While the impact of the other scenarios may differ slightly these differences will be best considered with actual extended period simulation hydraulic modeling of the system.

A brief analysis of the District’s system shows that:

1. Water Rights Capacity appears adequate to support the contemplated land uses in conjunction with existing intertie with SPU which provides for capacity for emergency fire suppression needs.
2. Some equalizing storage may be needed in the “Low Zone” HGL292ft although this would be most likely if fire suppression needs increased from the present 3,500GPM for 3hours. The additional demand due to the multi-family dwellings may not trigger the need for additional storage. Hydraulic modeling is needed to confirm this.
3. The existing transmission and distribution network appears to be mostly adequate although a few minor upgrades should be completed including a short section of 12” main on Ballinger in front of the Town Center and a short section of 8” main on 175<sup>th</sup> opposite the Town Center. One of these is being addressed with the McKinnon Creek pumping station currently under design.
4. Water quality needs to be considered to avoid increased reliance on McKinnon DW#3 and consequent increase in customer complaints.
5. Adequacy of the system should be considered in light of Federal Dept. Homeland Security requirements which are triggered once the District’s customer count crosses the DHS threshold of 1,000 customers.

## Dan Mundall, P.E.

---

**From:** Stephen Mundall <GIS@lfpwd.org>  
**Sent:** Tuesday, November 13, 2018 12:24 PM  
**To:** Alan Kerley; Dan Mundall  
**Subject:** Fwd: Lake Forest Park Town Center  
**Attachments:** Table from EIS Assumptions\_Town Center Plan\_November 9 2018 REV by Otak.pdf

----- Forwarded Message -----

**Subject:** Lake Forest Park Town Center  
**Date:** Fri, 9 Nov 2018 21:50:45 +0000  
**From:** Adam Isaacson <[Adam.Isaacson@otak.com](mailto:Adam.Isaacson@otak.com)>  
**To:** Stephen Mundall <[GIS@lfpwd.org](mailto:GIS@lfpwd.org)>

Hey Stephen,

Today I received a summary of the different scenarios for upzoning of the Town Center site that are to be considered for our EIS report. I've included a table in the attachment. You will see 4 scenario columns (Existing, Alt 1 – No Action, Alt 2 – Varied Form and Height, and Alt 3 – Uniform Form and Height). Can you take a look and provide some feedback regarding what the implications of each of the scenarios would be on the LFPWD facilities – capacity, water rights, distribution, planned future improvements, etc.? Your feedback will assist me with the Analysis and Mitigation portion of the EIS. Thank you for your continued support and for your time.

Regards,



Adam Isaacson | Civil Design Engineer, P.E.

11241 Willows Road NE, Suite 200 | Redmond, WA 98052  
Direct: 425.739.7955 | Cell: 206.713.5613 | Main: 425.822.4446  
[www.otak.com](http://www.otak.com)

# DESCRIPTION OF ALTERNATIVES & ASSUMPTIONS

## Town Center Subarea Plan Non-Project EIS

PRELIMINARY DRAFT—November 9, 2018




Land Use	Scenarios			
Non-Residential (SF)	Existing	Alt 1 - No Action	Alt 2 – Varied Form and Height	Alt 3 –Uniform Form and Height
Commercial	180,000	154,000	125,000	200,000
Medical/Dental	24,000	0	25,000	50,000
Bank	10,000	10,000	0	0
City Hall	20,000	20,000	32,000***	32,000***
New Civic/Community Space	0	0	20,000	20,000
Windemere Real Est. Office	16,000	16,000	16,000	16,000
Starbucks Coffee	2,500	2,500	2,500	2,500
Arco Gas Station	10 pumps	10 pumps	10 pumps	10 pumps
Lake Forest Bar and Grill	10,000	0	0	0
New Retail/Commercial Space	0	24,000	see above	see above
<b>Housing (Units)</b>				
Multi-family	0	Up to 700	Up to 1,200	Up to 1,500
<b>Parking (Spaces)</b>				
Town Center Commercial/Office, City Hall, and Other Owners	952	<p style="color: red;">-93*</p> <p style="color: red;">-336**</p> <p>+64 for retail on street and off street</p> <p>NET = 587</p> <p>commercial/ office demand @ 4/1000 GSF=906</p> <p>would need +319 spaces in structure or surface</p>	<p>280 on street/surface</p> <p>460 below grade/ structured</p> <p>commercial/ office demand @ 4/1000 GSF=842</p> <p>740 above+100 below</p>	<p>360 on street/surface</p> <p>600 below grade/ structured</p> <p>commercial/ office demand @ 4/1000 GSF= 1,154</p> <p>960 above +200 below</p>
Sound Transit Park and Ride Structure/Shared Structure	0	+300 Total = 300	+300 (shared) +100 retail/ City use Total = 400	+300 (shared) +200 retail/ City use Total = 500
Parking for New MF Housing Units (assumes a 1.05/unit ratio slightly above King County right sized parking model calculations); these would be located below grade or at grade in structure; also could be some surface				


\* Displaced by new parking structure some to the south and all to the north of existing medical office building

\*\* Displaced by new MF housing/retail – all in the northern area of Town Center site

\*\*\* Assumes 12,000 GSF expansion of City Hall; two levels at approx. 6,000 GSF each; assumes additional civic/community space which could be frontage to parking structure of 20,000 GSF and/or combination thereof

# D4





## SEWER FLOW CALCULATIONS

12/11/2018

Peaking Factor	3
Minutes per day	1440
Residential Occupancy per unit	2.4

Per 11/14/18 Mandi Roberts email

\*Based on per capita method outlined in WSDOE Orange Book 2008

## SEWER FLOW CALCULATIONS

12/11/2018

<b>ALTERNATIVE 1 - NO ACTION</b>		<b>Sewer Flow*</b>	
		<b>Square Feet</b>	<b>Gallons per day</b>
Non-Residential			
Commercial		154000	145800
Restaurant		50000	
General Commercial		104000	
Medical/Dental		0	0
Bank		10000	2000
City Hall		20000	2000
New Civic/Community Space		0	0
Windemere Real Est. Office		16000	1600
Starbucks Coffee		2500	6250
Arco Gas Station (No. of pumps listed, not square feet)		10	120000
Lake Forest Park Bar & Grill		0	0
New Retail/Commercial Space		24000	4800
<b>Housing</b>			
Multi-Family		700	168000
<b>Parking (Spaces)</b>			<b>0</b>
Town Center Commercial/Office, City Hall, and Other Owners		587	0
		906	0
		319	0
Sound Transit Park & Ride Structure/Shared Parking		300	0
	<b>TOTAL GPD</b>	<b>450450</b>	
	<b>GPM</b>	<b>313</b>	
	<b>Peak GPM</b>	<b>938</b>	

\*Based on per capita method outlined in WSDOE Orange Book 2008

## SEWER FLOW CALCULATIONS

12/11/2018

ALTERNATIVE 2 - VARIED FORM AND HEIGHT		Sewer Flow*	
Non-Residential		Square Feet	Gallons per day
Commercial		125000	140000
	Restaurant	50000	
	General Commercial	75000	
Medical/Dental		25000	12500
Bank		0	0
City Hall		32000	3200
New Civic/Community Space		20000	200
Windemere Real Est. Office		16000	1600
Starbucks Coffee		2500	6250
Arco Gas Station (No. of pumps listed, not square feet)		10	120000
Lake Forest Park Bar & Grill		0	0
New Retail/Commercial Space		0	0
<b>Housing</b>			
Multi-Family		1200	288000
<b>Parking (Spaces)</b>			<b>0</b>
Town Center Commercial/Office, City Hall, and Other Owners		280	0
		460	0
		842	0
		740	0
		100	0
Sound Transit Park & Ride Structure/Shared Parking		400	0
	<b>TOTAL GPD</b>	<b>571750</b>	
	<b>GPM</b>	<b>397</b>	
	<b>Peak GPM</b>	<b>1191</b>	
			<b>Average Day</b>
			<b>Average Day</b>


\*Based on per capita method outlined in WSDOE Orange Book 2008

## SEWER FLOW CALCULATIONS

12/11/2018

ALTERNATIVE 3 - UNIFORM FORM AND HEIGHT		Sewer Flow*	
Non-Residential		Square Feet	Gallons per day
Commercial		200000	155000
	Restaurant	50000	
	General Commercial	150000	
Medical/Dental		50000	25000
Bank		0	0
City Hall		32000	3200
New Civic/Community Space		20000	200
Windemere Real Est. Office		16000	1600
Starbucks Coffee		2500	6250
Arco Gas Station (No. of pumps listed, not square feet)		10	120000
Lake Forest Park Bar & Grill		0	0
New Retail/Commercial Space		0	0
<b>Housing</b>			
Multi-Family		1500	360000
<b>Parking (Spaces)</b>			0
Town Center Commercial/Office, City Hall, and Other Owners		360	0
		600	0
		1154	0
		960	0
		200	0
Sound Transit Park & Ride Structure/Shared Parking		500	0
<b>TOTAL GPD</b>		<b>671250</b>	
<b>GPM</b>		<b>466</b>	
<b>Peak GPM</b>		<b>1398</b>	
20 SF per patron			
Use 'Shopping centers'			
Use 'Doctor's office in medical center'			
Use 'Community Colleges', assume 150 SF per person			
Use 'Picnic Areas', assume 500 SF per person			
Use 'Community Colleges', assume 150 SF per person			
20 SF per patron			
Use 'Service Station', 50 vehicles per hour per pump			
Use 'Dwellings', 2.4 people per unit			
No sewer flow generated			

\*Based on per capita method outlined in WSDOE Orange Book 2008



**Figure C1-1. Ratio of Peak Hourly Flow to Design Average Flow**

WSDOE Orange Book 2008

**Table G2- 2. Design Basis for New Sewage Works**

<b>Discharge Facility</b>	<b>Design Units</b>	<b>Flow*</b> (gpd)	<b>BOD</b> (lb/day)	<b>SS</b> (lb/day)	<b>Flow Duration</b> (hr)
Dwellings	per person	100	0.2	0.2	24
Schools with showers and cafeteria	per person	16	.04	.04	8
Schools without showers and with cafeteria	per person	10	.025	.025	8
Boarding schools	per person	75	0.2	0.2	16
Motels at 65 gal/person (rooms only)	per room	130	0.26	0.26	24
Trailer courts at 3 persons/trailer	per trailer	300	0.6	0.6	24
Restaurants	per seat	50	0.2	0.2	16

<b>Discharge Facility</b>	<b>Design Units</b>	<b>Flow*</b> (gpd)	<b>BOD</b> (lb/day)	<b>SS</b> (lb/day)	<b>Flow Duration</b> (hr)
Interstate or through-highway restaurants	per seat	180	0.7	0.7	16
Interstate rest areas	per person	5	0.01	0.01	24
Service stations	per vehicle serviced	10	0.01	0.01	16
Factories	per person per 8-hr shift	15-35	0.03-0.07	0.03-0.07	Operating period
Shopping centers	per 1,000 sq ft of ultimate floor space	200-300	0.01	0.01	12
Hospitals	per bed	300	0.6	0.6	24
Nursing homes	per bed	200	0.3	0.3	24
Homes for the aged	per bed	100	0.2	0.2	24
Doctor's office in medical center	per 1,000 sq ft	500	0.1	0.1	12
Laundromats, 9 to 12 machines	per machine	500	0.3	0.3	16
Community colleges	per student and faculty	15	0.03	0.03	12
Swimming pools	per swimmer	10	0.001	0.001	12
Theaters, drive-in type	per car	5	0.01	0.01	4
Theaters, auditorium type	per seat	5	0.01	0.01	12
Picnic areas	per person	5	0.01	0.01	12
Resort camps, day and night, with limited plumbing	per campsite	50	0.05	0.05	24
Luxury camps with flush toilets	per campsite	100	0.1	0.1	24

\*Includes normal infiltration

